

CERTIFICATE OF CONFORMITY

(mandatory certification)

No. C-FI.ПБ06.В.01213

No. 0000929

APPLICANT Saint-Gobain Construction Products Rus LLC. Registered address and business address: 140301, Moscow Region, Egorievsk, Smychka Street, bld. 60. OGRN 1025001466379. Phone: (495) 775-15-10, Fax: (495) 775-15-11.

MANUFACTURER SAINT-GOBAIN RAKENNUSTUOTTEET OY. Registered address and business address: Kerkkolankatu 37-39, FIN-05801, P.O.Box 250, Hyvinkaa, Finland
Phone +3581945601, Fax: +3581945602(67).

CERTIFYING BODY Certifying Body "Ognestoykost", ZAO "Center of certification and tests "Ognestoykost". 109428, Moscow, 2-ya Institutskaya Street, bld.6. Phone (495)70-32-83, Fax (495)709-32-84.

OGRN: 1105018003936. Certificate of Accreditation No. TRPB.RU.PB06 [ТРПБ.РУ.ПБ06] was issued by Supervisory Activities Department of the RF Ministry for Emergency Situations.

CERTIFIES THAT THE PRODUCT

Glass wool (fiberglass) thermal insulation slabs ISOVER, SoundProtect, PitchedRoof, OL-E, OL-Pe, OL-P, OL-TOP (see attached list No. 0000641). Batch production.

CERTIFIES THAT THE PRODUCT

Glass wool (fiberglass) thermal insulation slabs ISOVER, SoundProtect, PitchedRoof, OL-E, OL-Pe, OL-P, OL-TOP (see attached list No. 0000641). Batch production.

National Product Classification

57 6300

Code 005: Universal Codifier of Issue

Article:

Goods Nomenclature for Foreign Economic Activities of the Russian Federation:

7019 39 000 9

CONFORMS TO REQUIREMENTS

OF TECHNICAL REGULATION (TECHNICAL REGULATIONS)

Technical regulations "On fire safety requirements" (the Federal Law No. 123-FZ dated 22.07.2008). SoundProtect, PitchedRoof, OL-E, OL-Pe, OL-P: group of combustibility – incombustible (GOST 30244-94, method 1); OL-TOP: group of combustibility - G1 (GOST 30244-94), flammability group - B1 (GOST 30402-96), group of smoke-generating capacity - D1 (GOST1 2.1.044-89*), group of toxicity of combustion products - T2 (GOST 12.1.044-89*).

CONDUCTED EXAMINATIONS (TESTS) AND MEASUREMENTS

Certification test reports No. 40 s/sm-2015 dated 30.07.2015, No. 45 s/sm-2015 dated 07.08.2015

Testing Center Ognestoykost ZAO "Center of certification and tests "Ognestoykost", Certificate reg. No. TRPB.RU.IN27 [ТРПБ.РУ.ИH27] dated 07.10.2010; Report on analyses of production state No. 1006 str/sm/op dated 03.06.2015 Certifying Body Ognestoykost ZAO "Center of certification and tests "Ognestoykost", Certificate reg. No. TRPB.RU.PB06 [ТРПБ.РУ.ПБ06] issued on 07.10.2010;

SUBMITTED DOCUMENTS

Market access certification mark is placed on: box (packaging), accompanying technical documentation.

DURATION OF VALIDITY OF CONFORMITY CERTIFICATE

from 15.08.2015 to 14.08.2020

/Certification stamp/

Head (Deputy Head) of certifying body

/Signature/ **A.V.Rzhankovskiy**

Expert (experts)

/Signature/ **L.N.Sazonova**

ANNEX
TO CERTIFICATE OF CONFORMITY No. C-FI.ПБ06.В.01213
(mandatory certification)

No. 0000641

List of products subject to Certificate of Conformity

National Product Classification Code 005 Goods Nomenclature for Foreign Economic Activities of the Russian Federation	Name, type, models of homogeneous product, components of product or complex	Identification of documents for manufacturing the product
57 6300 7019 39 000 9	Glass wool (fiberglass) thermal insulation slabs ISOVER of model: - SoundProtect (density 14±10% kg/m ³ , organic matter content, % of weight, 5,5±0,5); - PitchedRoof (density 15±10% kg/m ³ , organic matter content, % of weight, 5,5±0,5); - OL-E (density 40-67 kg/m ³ , organic matter content, % of weight, 7,5±0,5); - OL-Pe (density 50-90 kg/m ³ , organic matter content, % of weight, 8,0±0,5); - OL-P (density 70-86 kg/m ³ , organic matter content, % of weight, 8,0±0,5); - OL-TOP (density 104-133 kg/m ³ , organic matter content, % of weight, 10,0±0,5, folded with glass-fiber mat).	EN 13162 "Construction thermal insulation materials"

/Certification stamp/

Head (Deputy Head) of certifying body

/Signature/ **A.V.Rzhankovskiy**

Expert (experts)

/Signature/ **L.N.Sazonova**